



**KERALA WATER AUTHORITY**  
**QUALITY CONTROL DISTRICT LAB KASARAGOD, VIDYANAGAR**  
**WATER ANALYSIS REPORT**

Tele phone No : 04994 255791  
email : qclabkasaragod@gmail.com

Report No - KWA/QA/R/02/361/J/46/69		24/02/2024
Customer Name and Address <b>Amrita Vidyalayam A</b> <b>Amrita vidyalauam Amritagiri</b> <b>Kalyanroad Balla</b> <b>Kanhangad Kasaragod 671531</b> <b>Phone : 9188120462</b> <b>( Non - Domestic)</b>	1. Date of receipt	:23/02/2024
	2. Sample Provided by	Customer (QUA_111514)
	3. Sample Code	24/24 (31)
	4. Source of Sample	Bore Well
	5. Sample quantity	: 1 litre
	6. Test performing dates	From:23/02/2024 To : 24/02/2024

Sl No	Characteristics	Unit	Test Method	Acceptable limits as per IS 10500-2012	Result
1	Taste		IS 3025(part 8)	Agreeable	--
2	Electrical Conductivity at 25°C	(micro mhos/cm)	IS 3025 (part 14) -2013 (Reaffirmed 2019)		95.22
3	Acidity	(mg/litre)	IS 3025 (part 22) -1986 (Reaffirmed 2019)		--
4	Sulphate (as SO <sub>4</sub> )	(mg/litre)	APHA23rd Edition (Turbidimetric method)	200	--
5	Fluoride (as F)	(mg/litre)	IS 3025 (part 60) -2008 (Reaffirmed 2013)	1	--
6	Iron (as Fe)	(mg/litre)	IS 3025 (part 53) -2003 (Reaffirmed 2014)	1	0.30
7	Nitrate (as NO <sub>3</sub> )	(mg/litre)	APHA23rd Edition (UV Screening method)	45	BDL
8	Residual Chlorine	(mg/litre)	IS 3025 (Part 26)-2021	0.2	--

**Remarks:**

The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the approval of the laboratory.

BDL-Below Detection Limit

Authorised By

Quality Manager

Quality Control District Lab  
Kerala Water Authority  
Vidyanagar, Kasaragod - 671113

\* End Of Report\*

KWA/QC/DL/KSD/R/17

Issue No: 03

Issue Date : 25.02.2023

Rev Date:  
Rev No: 002 25.02.2023